

Sample Report

AEROBARRIER™

Breakthrough Envelope Sealing Technology



Certificate of Completion

Envelope Sealing Performed For:
 Your Project Name Here
 Rochester, NY 14624


Overall Sealing Results

When we arrived,
 YOUR HOME HAD:
2507.9 CFM of Leakage, equivalent to a
312.6 Square Inch Hole or **5.4 Air Changes per Hour**
(for your 3500 square-foot structure enclosing an approximate volume of 28000 cubic feet).

After we finished,
 YOUR HOME HAS:
297.8 CFM of Leakage, equivalent to a
37.1 Square Inch Hole or **0.6 Air Changes per Hour**

This corresponds to a **88.1% Reduction** in Envelope Leakage.

Note: Envelope leakage and air-change results are calculated at a standard pressure of 50 Pa.



Aeroseal Technician
 Aeroseal Case ID **9928**
 Date of Seal **2/19/2019**
 System Description **Home Envelope**
 Seal Description **Envelope Sealing**
 Hardware **EnvelopeSeal**

Envelope Sealing Performed By:
 US Ceiling Corp
 1085 Gravel Road
 Webster, NY 14580
 Phone: 585.872.4527